

Number	19-001535-PR07 (NW-K02-09-en-02)		
Owner	HANGZHOU ZHIJIANG SILICONE CHEMICALS CO., LTD. No.1717,Century Avenue Xiaoshan District P.C. 311 200 Hangzhou Zhejiang China		
Product	Sealant for insulating glass units		
Designation	Shipping name: Finotech® 8000 or Finotech® SQ 110 or Jinshu® 7800		
Details	Manufacturer HANGZHOU ZHIJIANG SILICONE, CHEMI- CALC CO., LTD. 311 200 - Hangzhou Zhejiang ; Material Based on silicone; Color black		
Special features			
Result			
	5.3 Adhesion	The requirements of EN 1279-4:2018-07 chapter 5.3, stress- strain behaviour, are fulfilled	
	5.5.2 Moisture va- pour transmission rate	$MVTR_{\text{(lowest single value)}} = 15.2 \text{ g}_{\text{H}_2\text{O}}/(\text{m}^2 \cdot \text{d})$	

Basis *)

EN 1279-4:2018-07
EN ISO 10563:2017-09
EN ISO 11358-1:2014-07
EN ISO 1183-1:2019-04
*) and corresponding national versions
(e.g. DIN EN)

Test report: 19-001535-PR07 PB-K02-09-en-02

Replaces ift-Nachweis:
19-001535-PR07 NW-K02-09-en-01 dated 15.10.2020

Instructions for use

The results obtained can be used as evidence in accordance with the above basis.

Validity

There is no time limit.
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

The data and results given relate solely to the tested/described specimen. This test/evaluation does not allow any statement to be made on further characteristics of the present structure regarding performance and quality.


Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

ift Rosenheim
28.10.2020



Michael Freinberger, Dipl.-Ing. (FH)
Head of Testing Department
Material Testing



Jennifer Seyfang, Dipl.-Ing. (FH)
Operating Testing Officer
Material Testing

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: 6E3-B375E